

Tucumcari Consumer Confidence Report 2011

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from 11 wells which are between 300 and 400 feet deep and are in the Entrada Sandstone Formation, Tucumcari Basin.

Source water assessment and its availability

The Tucumcari Water System is well maintained and operated, and sources of drinking water are generally protected from potential sources of contaminations based on well construction, hydrogeologic settings, and system operations and management. In July 2003, the New Mexico Environment Department-Drinking Water Bureau issued a Source Water Assessment and Protection Program (SWAPP) report for the Tucumcari Water System. Findings of the SWAPP report indicate that the source susceptibility rank of the entire water system is High. Please contact the Tucumcari Water System to discuss the findings of the SWAPP report.

Table 8

Source Name	SOURCE SUSCEPTIBILITY RANKING				
	Sensitivity Rank	Vulnerability Rank	Susceptibility Rank	Operational Exceptions	Final Rank
Hoover Well #1	Moderate	High	Moderately High -		Moderately High
Hoover Well #2	Moderate	High	Moderately High		Moderately High
Metro Well #4	Moderately Low	Low	Moderately Low -		Moderately low
Metro Well #6	Moderately Low	High	Moderately High	>3 PSOC	High
Metro Well #7	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #8	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #10a	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #15	Low	Low	Moderately Low	>3 PSOC	Moderate
Town Well #12A	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #13	Moderate	Low	Moderately Low	Nitrate Monitoring-	Moderate
Town Well #16	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #17a	Moderate	High	Moderately High	>3 PSOC	High
Town Well #18	Moderate	High	Moderately High	>3 PSOC	High
Town Well #19	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #20	Moderately Low	High	Moderately High	>3 PSOC	High

PSOC: Potential Source of Contaminants

1New Mexico Environment Department, 2003. Source Water Assessment & Protection Program Report of Tucumcari Water Utility, Public Water System #28020, July 2003.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

You can attend City Commission meetings the second and fourth Thursday of each month.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Tucumcari is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
TTHMs [Total Trihalomethanes] (ppb)	NA	80	12.6	ND	12.6	2009	No	By-product of drinking water disinfection
Chlorine (as Cl ₂) (mg/L)	4	4	0.69	0.24	1.71	2011	No	Water additive used to control microbes
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	2.1	1.1	2.1	2011	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic (ppb)	0	10	2.2	ND	2.2	2011	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.065	0.036	0.065	2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

Selenium (ppb)	50	50	10	5.2	10	2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Fluoride (ppm)	4	4	1.2	0.71	1.2	2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium (optional) (ppm)	NA	MPL	130	63	130	2011	No	Erosion of natural deposits; Leaching

Radioactive Contaminants

Radium (combined 226/228) (pCi/L)	0	5	0.3	0.24	0.3	2011	No	Erosion of natural deposits
Uranium (ug/L)	0	30	24	16	24	2011	No	Erosion of natural deposits
Alpha emitters (pCi/L)	0	15	8.9	1.38	8.9	2011	No	Erosion of natural deposits
Beta/photon emitters (pCi/L)	0	50	14.9	10.5	14.9	2011	No	Decay of natural and man-made deposits. The EPA considers 50 pCi/L to be the level of concern for Beta particles.

<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL¹</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
---------------------	-------------	-----------	-------------------	--------------------	---	-------------------	-----------------------

Inorganic Contaminants

Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2009	0	No	Corrosion of household plumbing systems; Erosion of natural
Lead - action level at consumer taps (ppb)	0	15	2	2009	1	No	Corrosion of household plumbing systems; Erosion of natural

¹Per U.S. EPA regulations a system is in compliance with lead and copper AL requirements as long as no more than 10% of samples exceed the ALs. In 2009 the Tucumcari Water System collected 20 samples for lead and copper analyses. Of these only 1 (5%) exceeded the AL for lead and none exceeded the AL for copper."

Additional Contaminants

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water

<u>Contaminants</u>	<u>State MCL</u>	<u>Your Water</u>	<u>Violation</u>	<u>Explanation and Comment</u>
Zinc (ppb)	NA	17	No	

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
mg/L	mg/L: Number of milligrams of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Charles Sandavol
Address: P.O. Box 1188
Tucumcari, NM 88401
Phone: (575) 461-3923
Fax: (575) 461-2049
E-Mail: csandova@cityoftucumcari.com
Website: cityoftucumcari.com

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.